

Two Rivers Water Reclamation Authority

One Highland Avenue • Monmouth Beach, New Jersey 07750

(732) 229-8578 • Fax (732) 870-1442

Fair Haven
Little Silver
Monmouth Beach

Oceanport
Shrewsbury
West Long Branch


TO: Property Owner/Builder/Developer
FROM: Gregory Seaman, Operations Manager
DATE: March 25, 2001
RE: TRWRA - Requirements for Sewer Connections
and Disconnections

• CONNECTIONS

1. The connection between the building sewer (house to curb) and the house connection (curb to main) must be inspected by TRWRA. **The Authority shall be notified a minimum of 48 hours in advance of the connection so an inspection can be scheduled.**
2. The cleanout must be installed per TRWRA's Rules and Regulations (drawing enclosed).
3. Any cleanout falling in a paved area (sidewalk, driveway etc.) must be protected with a metal valve box equal to Campbell Foundry Item #4155.
4. A 4" brass cap shall be installed on the cleanout.
5. Road opening permits are required.
6. All road restoration is the responsibility of the contractor.
7. All pavements must be saw cut.
8. An application for a sewer connection must be made with TRWRA (enclosed).
9. All applicable fees must be **paid in full prior** to the connection date.

• DISCONNECTIONS

1. The building sewer must be disconnected from the house connection and capped with an approved plug (check with TRWRA for location and pipe type). TRWRA personnel must inspect this.



GS: rs
Enclosures

"Setting The Standard In Water Reclamation"

Customer Towns: Eatontown • Fort Monmouth • Red Bank • Rumson • Sea Bright • Shrewsbury Township • Tinton Falls

Two Rivers Water Reclamation Authority

One Highland Avenue • Monmouth Beach, New Jersey 07750

(732) 229-8578 • Fax (732) 870-1442

Fair Haven
Little Silver
Monmouth Beach

Oceanport
Shrewsbury
West Long Branch

Application for Approval of Sewerage Facilities

1. Applicant's Name: _____

Address: _____

Telephone: _____

2. Interest of application if other than owner: _____

3. Location of Lot: _____

Street: _____

Block: _____

Lot (s) _____

4. Number of proposed lots sewered: _____

On existing sewers: _____

5. Construction of house for sale: yes or no _____

Others: _____

6. Fill out attached application for sewer connection showing desired depth and location of stub.

Signature of Applicant _____

RS
Application for Approval of Sewerage Facilities



"Setting The Standard In Water Reclamation"

Customer Towns: Eatontown • Fort Monmouth • Red Bank • Rumson • Sea Bright • Shrewsbury Township • Tinton Falls

FOR

TWO RIVERS WATER RECLAMATION AUTHORITY

DATE

FEE PAID

SEWER CONNECTION /
 DISCONNECTION

PROPERTY OWNER (PLEASE PRINT)

PRESENT ADDRESS

TELEPHONE

ADDRESS OF SEWER CONNECTION

LOT NO.

BLOCK NO.

PLUMBER OR SEWER CONTRACTOR (LICENSED)

ADDRESS

TELEPHONE

NOTES:

Show all required information on this sketch, on back of sheet, or on attachments.

The Authority will not assume any responsibility for back-up or flooding of any fixture that is lower than 8 inches above the rim of the nearest manhole in the street.

The Property Owner shall be liable to the Authority for any loss or damage to the Authority's facilities that may directly or indirectly be occasioned by the installation or use of the Building Sewer or any other cause.

The Property Owner grants permission to the Authority, its agents and employees, to enter upon the above described premises to inspect or test any present or future facilities which are connected to the Authority system.

Type of Structure:
Single Family Dwelling

Other

(Separate form to be completed)

Date by which connection must be made (90 days after notification)

SIGNED BY

Property Owner

Application Approved by

CURB

Preliminary Inspection

Inspected by


Date

Received by Board of Health, Borough of

Approved by

Final Approval


Date




EASEMENT - ?

PROPERTY LINE

IF THIS DETAIL DOES NOT FIT EXISTING CONDITIONS - USE BACK OF FORM



TYPICAL TRENCH SECTION
FOR HOUSE CONNECTION



STANDARD. DETAILS

TRWRA

REVISED JULY 13, 1990

FEBRUARY 15, 1989